

# ATTESTATION OF CONFORMITY

Issued to: EAGLERISE ELECTRIC & ELECTRONIC(JI AN)CO.,LTD  
West Zone, Ji An County Industrial Park, Ji An County, Jiangxi, China

For the product: LED Power Supply

Trade name:



Type/Model: VTS-200-24 DALI-2 0-10 IP65 L,  
VTS-200-24 DALI-2 0-10 L

Ratings: See annex

Manufactured by: EAGLERISE ELECTRIC & ELECTRONIC(JI AN)CO.,LTD  
West Zone, Ji An County Industrial Park, Ji An County, Jiangxi, China

Subject: Complete evaluation of electrical system of the appliances

Requirements: EN IEC 55015:2019 + A11:2020  
EN IEC 61547:2023  
EN IEC 61000-3-2:2019 + A1:2021 + A2:2024  
EN 61000-3-3:2013 + A1:2019 + A2:2021

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a test file / test report no 4937515.50/51.

This Attestation implies that the examined types are in accordance with the standards designated under the Electromagnetic Compatibility Directive (EMC) 2014/30/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This document does not authorize the use of any DEKRA approved mark.

Arnhem, 30 May 2025

Number: 4937515.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.,  
Guangzhou Branch

Miranda Zhou  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

# Annex

Document no. : 4937515.01AOC

Ratings:

Model	Input			Output		
	Voltage (VAC)	Max. Current(A )	Frequency (Hz)	Constant voltage (Vdc)	Normal working Current(A)	Max. Power(W)
VTS-200-24 DALI-2 0-10 IP65 L	220-240	1.2A	50/60 Hz	24	0-8.33A	200
VTS-200-24 DALI-2 0-10 L	220-240	1.2A	50/60 Hz	24	0-8.33A	200

End