



Ref. Certif. No

NO135925

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

LED Power Supply

## Name and address of the applicant

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD  
West Zone, Ji An County Industrial Park, Ji an County  
Jiangxi Province  
China

## Name and address of the manufacturer

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD  
West Zone, Ji An County Industrial Park, Ji an County  
Jiangxi Province  
China

## Name and address of the factory

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD  
West Zone, Ji An County Industrial Park, Ji an County  
Jiangxi Province  
China

Note: When more than one factory, please report on page 2

☐ Additional Information on Page 2Ratings and Principal characteristics  
Trademark /Brand (If any)PRI: max. 0.24 A, 220-240 V~, 0/50/60 Hz, Cl. II, more information see additional information  
EAGLERISE

## Customer's Testing Facility (CTF) Stage used

## Model/Type Ref

FLS-20-500 LD1 PRO, FLS-30-700 LD1 PRO, FLS-38-900 LD1 PRO, FLS-42-1050 LD1 PRO

## Additional information (If necessary may also be reported on Page 2)

☒ Additional Information on Page 2

## A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017  
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

## As shown in the Test Report Ref. No. which forms part of this Certificate

REP110326

This CB Test Certificate is issued by the National Certification Body

Philip Pedersen vei 11,  
NO-1366 Lysaker, Norway  
Date: 04-09-2025Signature: Juan Z Saussey  
Certification department



Ref. Certif. No

**NO135925**

### Additional Information (if necessary)

Centralized emergency power supply: 220-240 V DC

SEC: max. 42 W, max. 1.05 A, 27-40 Vd.c. (under load), max. 59 Vd.c. (no-load), EOFI: 100%

Independent type with terminal cover incl. strain relief. Built-in type without terminal cover. SELV, constant current output, thermal protected 110 °C, ta: 45 °C, tc: 80 °C / 85 °C



Philip Pedersen vei 11,  
NO-1366 Lysaker, Norway

Date: 04-09-2025

Signature: Juan Z Saussey  
Certification department