



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2025011002812721

NAME AND ADDRESS OF THE APPLICANT

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An
County, Jiangxi Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An
County, Jiangxi Province, P.R.China

NAME AND LOCATION OF THE FACTORY

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An
County, Jiangxi Province, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (LED Controlgear, Independent, Constant
Voltage Mode, SELV, Non-dimmable, Class I, IP67, ta:55°C, tc:90°C, Suitable For Direct Mounting
On Normally Flammable Material Surfaces, Temperature Declared Thermally Protected:110°C)
See Appendix. 220-240V~ 50/60Hz

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17625.1-2022;GB/T 17743-2021;GB/T 19510.1-2023;GB/T 19510.213-2023

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014).

Valid from: Sep.18,2025

Valid until: Sep.17,2030

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2025011002812721

Appendix: Page 1 of 1

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

序号	型号	输出		
		输出电压 (Vdc)	正常工作 电流 (A)	最大功率 (W)
1	VMS-50-48 IP67 L EXC	48	1.04	50
2	VMS-50-42 IP67 L EXC	42	1.19	50
3	VMS-50-36 IP67 L EXC	36	1.39	50
4	VMS-50-24 IP67 L EXC	24	2.08	50
5	VMS-50-12 IP67 L EXC	12	4.17	50
6	VMS-75-48 IP67 L EXC	48	1.56	75
7	VMS-75-42 IP67 L EXC	42	1.78	75
8	VMS-75-36 IP67 L EXC	36	2.08	75
9	VMS-75-24 IP67 L EXC	24	3.125	75
10	VMS-75-12 IP67 L EXC	12	6.25	75

注：输入均为 220-240V~ 50/60Hz。

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.