



Attestation of Conformity

No. N8A 105345 0002 Rev. 00

Holder of Attestation: **Eaglerise Electric & Electronic
(Ji'an) Co., Ltd.**

Southwest Corner of Panlong Road and Chaoyang Road
Ji'an Industrial Park
343100 Ji'an County, Jiangxi Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic controlgear for LED modules
(Constant Current LED Power Supply)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 211-902732-000

Date, 2026-07-03

(Taylor Yao)

Page 1 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 105345 0002 Rev. 00

Model(s): ITS DALI-2 15/220-240/350 CS;
ITS DALI-2 20/220-240/500 CS;
ITS DALI-2 30/220-240/700 CS;
ITS DALI-2 42/220-240/1050 CS;
ITS DALI-2 60/220-240/1500 CS;
ITS FIX 20/220-240/500 CS;
ITS FIX 30/220-240/700 CS;
ITS FIX 42/220-240/1050 CS;
ITS FIX 60/220-240/1500 CS

Brand: OSRAM

OSRAM

Parameters:

Rated Input Voltage: 220-240VAC or 220-240VAC/DC

Rated Frequency: 50/60Hz or 0/50/60Hz

Rated Input Current: See below table for details

Rated Output: See below table for details

Protection Class: Class II (for ITS DALI-2 15/220-240/350 CS);

Class II (with endcap) (for all other models)

Protection against Electric Shock: SELV

Degree of Protection: IP20 (for ITS DALI-2 15/220-240/350 CS);

IP20 (with endcap) (for all other models)

Method of Installation: Independent (for ITS DALI-2 15/220-240/350 CS);

Independent (with endcap)/ Built-in (without endcap) (for all other models)

Type of Output: Constant current type

ta: See below table for details

tc: See below table for details

Tested according to: EN IEC 61347-2-13:2024
EN IEC 61347-1:2024
EN 62493:2015/A1:2022

Page 2 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

Attestation of Conformity

No. N8A 105345 0002 Rev. 00

Seri es	Model	Rated Input Current (A)	P _{rated} (W)	Output Voltage (VDC)	I _{rated} (mA)	U _{out} (VDC)	ta (°C)	tc (°C)
1	ITS DALI-2 15/220-240/350 CS	0.11	4.2	9-42	100	60	-20 to +50	80
			5.0		120			
			6.3		150			
			7.6		180			
			8.4		200			
			10.5		250			
			12.6		300			
			14.7		350			
2	ITS DALI-2 20/220-240/500 CS	0.15	6.8	10-45	150	60	-20 to +50	80
			9.0		200			
			11.3		250			
			13.5		300			
			15.8		350			
			18.0		400			
			18.9	10-42	450			
			20.0	10-40	500			
2	ITS DALI-2 30/220-240/700 CS	0.2	15.8	10-45	350	60	-20 to +50	80
			18.0		400			
			20.2		450			
			22.5		500			
			24.8		550			
			27.0		600			
			29.3		650			
			29.4	10-42	700			
3	ITS DALI-2 42/220-240/1050 CS	0.27	31.5	10-45	700	60	-20 to +45 (950-1050mA) -20 to +50 (700-900mA)	85
			33.8		750			
			36.0		800			
			38.3		850			
			40.5		900			
			41.8	10-44	950			
			42.0	10-42	1000			
			42.0	10-40	1050			
4	ITS DALI-2 60/220-240/1500 CS	0.35	38.4	15-48	800	60	-20 to +45 (1200-1500mA) -20 to +50 (800-1050mA)	90
			43.2		900			
			48.0		1000			
			50.4		1050			
			57.6		1200			
			54.6	15-42	1300			
			58.8		1400			
			60.0	15-40	1500			
5	ITS FIX 20/220-240/500 CS	0.2	6.3	23-42	150	59	-20 to +50	80
			8.4		200			
			10.5		250			
			12.6		300			
			14.7		350			
			16.8		400			
			18.9		450			
			20	23-40	500			
5	ITS FIX 30/220-240/700 CS	0.2	14.7	23-42	350	59	-20 to +50	80
			16.8		400			

Page 3 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

Attestation of Conformity

No. N8A 105345 0002 Rev. 00

			18.9		450			
			21.0		500			
			23.1		550			
			25.2		600			
			27.3		650			
			29.4		700			
5	ITS FIX 42/220-240/1050 CS	0.27	29.4	23-42	700	59	-20 to +45 (950-1050mA)	85
			31.5		750			
			33.6		800			
			35.7		850			
			37.8		900			
			39.9		950			
			42.0		1000			
			42.0	23-40	1050			
6	ITS FIX 60/220-240/1500 CS	0.37	33.6	24-42	800	59	-20 to +50	85
			37.8		900			
			42.0		1000			
			46.2		1100			
			50.4		1200			
			54.6		1300			
			58.8		1400			
			60.0	24-40	1500			