



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2026011002895029

NAME AND ADDRESS OF THE APPLICANT

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An
County, Jiangxi Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An
County, Jiangxi Province, P.R.China

NAME AND LOCATION OF THE FACTORY

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An
County, Jiangxi Province, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (LED Controlgear, Independent, Constant
Current Mode, SELV, Class I, IP20, ta:60°C, tc:85°C, Temperature Declared Thermally Protected:
110°C, Suitable For Direct Mounting On Normally Flammable Material Surfaces)
See Appendix; 120-277V ~ 50/60Hz

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17625.1-2022;GB/T 17743-2021;GB/T 19510.1-2023;GB/T 19510.213-2023

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014).

Valid from: Sep.15,2026

Valid until: Sep.14,2031

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



SIGNATURE:



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2026011002895029

Appendix: Page 1 of 1

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

型号	输入			输出			
	电压	电流	频率	电流	电压	最大 工作 电压	额 定 功率
	(VAC)	(mA)	(Hz)	(mA)	(Vdc)	(Vdc)	(W)
FMX-50-1050 LD	120-277	600	50/60	150	9-54	60	8.1
				200	9-54		10.8
				250	9-54		13.5
				300	9-54		16.2
				350	9-54		18.9
				400	9-54		21.6
				500	9-54		27
				600	9-54		32.4
				700	9-54		37.8
				750	9-54		40.5
				800	9-54		43.2
				850	9-54		45.9
				900	9-54		48.6
				950	9-52.6		50
				1000	9-50		50
				1050	9-47.6		50

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.