

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED Power Supply

Name and address of the applicant

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji An County Jiangxi, China

Name and address of the manufacturer

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji An County Jiangxi, China

Name and address of the factory

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji An County Jiangxi, China*When more than one factory*☐ Additional information on page 2

Ratings and principal characteristics

Product data

Ratings: 220-240 V, 0/50/60 Hz, SELV, constant current output, 110 °C
thermal protection, EL mark,
built-in type: double insulation;
independent type: Class II, IP20;
other information refers to model list of test report for details

Trademark / Brand (if any)

 or  or  or 
EAGLE, EAGLERISE, EAGLELUX or EAGLUX

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FLS-16-450 DALI-2 LA ADV, FLS-20-500 DALI-2 DT8 LN ADV,
FLS-42-1050 DALI-2 DT8 LN ADV and FLS-42-1050 DALI-2 LD2 PRO

Additional information

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with


IEC 61347-1:2024 and IEC 61347-2-13:2024

As shown in the Test Report Ref. No. which forms part of this Certificate

4951134.50

National differences:
EU Group Differences, GB

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-07-01

Signature: Miranda Zhou