本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2026011002856771

NAME AND ADDRESS OF THE APPLICANT

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An County, Jiangxi Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An County, Jiangxi Province, P.R.China

NAME AND LOCATION OF THE FACTORY

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An County, Jiangxi Province, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (LED Controlgear, Independent, Constant Current Mode, SELV, Class Ⅱ, IP20, ta:45℃, tc:80℃, Controlled Port Dimming, Temperature Declared Thermally Protected: 110℃, Suitable For Direct Mounting On Normally Flammable Material Surfaces)

See Appendix; 220-240V ~ 50/60Hz

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17625.1-2022;GB/T 17743-2021;GB/T 19510.1-2023;GB/T 19510.213-2023

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014).

Valid from: Mar.30,2026 Valid until: Mar.29,2031

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

SIGNATURE:

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

中国质量认证中心有限公司 1101061026946

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2026011002856771

序号	型号	输入参数	输出参数			
		输入电流（A）	输出电流(mA)	输出电压(VDC)	最大输出电压（Max. VDC）	输出功率(Max.W)
1.	FLS-12-350 0-10 LA ADV	0.09	200	15-42	59	8.4
			250			10.5
			300			12.6
			350	15-38		13.3

输入：220-240V～ 50/60Hz

This page is attached to the certificate and should be used at the same time as the certificate page.

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE