

ATTESTATION OF CONFORMITY

Issued to: Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.
No.4 East Huanzhen Road, Beijiao Shunde, 528000 Foshan Guangdong, China

For the product: LED Power Supply

Trade name: 

Type/Model: FDS-12-350 DALI-2 LD, FDS-30-700 DALI-2 LD, FDS-40-1050 DALI-2 LD

Ratings: Built-in type, double insulation, non-inherently shorted circuit proof, 110 °C thermal protection, SELV constant current output, IP20, EL mark;
Other information refers to Attachment 5 of test report for details

Manufactured by: Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.
No.4 East Huanzhen Road, Beijiao Shunde, 528000 Foshan Guangdong, China

Requirements: EN 61347-1:2015 + A1:2021
EN 61347-2-13:2014 + A1:2017

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 4388149.50.

This Attestation implies that the examined types are in accordance with the standards designated under the Low Voltage Directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 21 July 2022

Number: 4388149.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.,
Guangzhou Branch

Miranda Zhou
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

