

Ref. Certif. No.

NO123806

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Type of Manufacturer's Testing Laboratories used Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body



Philip Pedersens vei 11, NO-1366 Lysaker, Norway

Date: 13-09-2022

Signature: Juan Z. Saussey Certification Department

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd. No.4, East Huanzhen Road, Beijiao Shunde Foshan Guangdong China Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd. No.4, East Huanzhen Road, Beijiao Shunde Foshan Guangdong China

Additional information on page 2

LED Power Supply

PRI: LV supply: max. 0.32 A, 220-240 V~, 50/60 Hz, Cl. II



FLS-15-350 0-10 LA, FLS-25-600 0-10 LA, FLS-44-1050 0-10 LA

Additional information on page 2

IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017 481058



Foshan Eaglerise Power Science & Technology (Shunde)EAGLERISE ELECTRCo., Ltd.LTDNo.4, East Huanzhen Road, Beijiao ShundeWest Zone, Ji An CouFoshan GuangdongJiangxi ProvinceChinaChina

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD West Zone, Ji An County Industrial Park, Ji an County Jiangxi Province

Additional information(if necessary)

PF: 0.4C-0.95 for model FLS-15-350 0-10 LA, PF: 0.4C-0.95 for model FLS-25-600 0-10 LA, PF: 0.6C-0.97 for model FLS-44-1050 0-10 LA. SEC: FLS-15-350 0-10 LA: Max. 14.7 W, 0.12-0.35 A, 9-42 Vd.c. (under load), max. 59 Vd.c. (no-load); FLS-25-600 0-10 LA: Max. 25.2 W, 0.2-0.6 A, 9-42 Vd.c. (under load), max. 59 Vd.c. (no-load); FLS-44-1050 0-10 LA: Max. 44.1 W, 0.65-1.05 A, 9-42 Vd.c. (under load), max. 59 Vd.c. (no-load). Independent type; SELV, constant current output, thermal protected 110°C, ta: 45°C, tc: 85°C



Philip Pedersens vei 11, NO-1366 Lysaker, Norway



Signature: Juan Z. Saussey Certification Department