



Ref. Certif. No.

**NO124495**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

### CB TEST CERTIFICATE

Product

LED Power Supply

Name and address of the applicant

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.  
No.4, East Huanzhen Road, Beijiao Shunde  
Foshan Guangdong  
China

Name and address of the manufacturer

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.  
No.4, East Huanzhen Road, Beijiao Shunde  
Foshan Guangdong  
China

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

PRI: LV supply: max. 0.12 A, 220-240 V~, 0/50/60 Hz, Cl. II  
 $\lambda$ : 0.4C- 0.95 (For FLS-16-400 DALI-2 LD),  
 $\lambda$ : 0.35C- 0.95 (For FLS-16-400 DALI-2 LD1)

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FLS-16-400 DALI-2 LD, FLS-16-400 DALI-2 LD1

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017  
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

REP001863

This CB Test Certificate is issued by the National Certification Body



Philip Pedersens vei 11,  
NO-1366 Lysaker, Norway

Date: 04-11-2022

Signature: Juan Saussey  
Certification Department



Ref. Certif. No.

**NO124495**

EAGLERISE ELECTRIC & ELECTRONIC (JI AN)  
CO., LTD  
West Zone, Ji an County Industrial Park, Ji an  
County, Jiangxi Province,  
China

Foshan Eaglerise Power Science & Technology  
(Shunde) Co., Ltd  
No.4, East Huanzhen Road, Beijiao Shunde,  
Foshan, Guangdong,  
China

**Additional information (if necessary)**

Centralized emergency power supply: 198-264 Vdc

SEC: Max. 16.8 W, max. 0.4 A, 9-42 Vd.c. (under load), max. 57 Vd.c. (no-load).

Independent type with terminal cover incl. strain relief. Built-in type without terminal cover. EOFI: 15%, SELV, constant current output, thermal protected 110 °C, ta: 50 °C, tc: 70 °C



Philip Pedersens vei 11,  
NO-1366 Lysaker, Norway

**Date:** 04-11-2022

**Signature:** Juan Saussey  
Certification Department