


A sample of the following product has been tested and is stated by Nemko to be in conformity with the applicable European standards referred below.

<b>Product</b>	LED Power Supply	
<b>Manufacturer</b>	Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd. No.4, East Huanzhen Road, Beijiao Shunde Foshan Guangdong China	
<b>Factory</b>	See page 2	
<b>Project Number</b>	PRJ0011675	
<b>Model/Type Ref.</b>	FLS-16-400 DALI-2 LD, FLS-16-400 DALI-2 LD1	
<b>Trademark</b>		
<b>Ratings</b>	PRI: LV supply: max. 0.12 A, 220-240 V~, 0/50/60 Hz	
<b>Principal Characteristics</b>	CI. II. $\lambda$ : 0.4C- 0.95 (For FLS-16-400 DALI-2 LD), $\lambda$ : 0.35C- 0.95 (For FLS-16-400 DALI-2 LD1). More information see additional information	
<b>A sample of the product was tested and found to be in conformity with</b>	<b>Safety</b>	EN 61347-1:2015;A1 EN 61347-2-13:2014;A1 EN 62493:2015
	<b>EMC</b>	EN IEC 55015:2019;A11 EN 61547:2009 EN IEC 61000-3-2:2019;A1 EN 61000-3-3:2013;A1;A2
	<b>Test Report Ref. No.</b>	REP001863 and REP002007

It may therefore be presumed that the tested sample of the product is in conformity with the technical provisions of the following European Directives including the latest amendments, and with national legislation implementing these Directives:

- Low Voltage Directive 2014/35/EU
- EMC Directive 2014/30/EU

Provided that other applicable Directive requirements are satisfied, the manufacturer (or the European authorized representative), may draw up an EC/EEA Declaration of Conformity and affix the CE-marking to each conforming product.

**Additional Information** See page 2

**Additional model(s)**



# ATTESTATION OF CONFORMITY WITH EUROPEAN DIRECTIVE



## Additional information

Centralized emergency power supply: 198-264 Vdc  
SEC: Max. 16.8 W, max. 0.4 A, 9-42 Vd.c. (under load), max. 57 Vd.c. (no-load).  
Independent type with terminal cover incl. strain relief. Built-in type without terminal cover. EOFI: 15%, SELV, constant current output, thermal protected 110 °C, ta: 50 °C, tc: 70 °C

The product complies with standard EN 61347-2-13:2014, EN 61347-1:2015, EN 61000-3-2:2014 and EN 61000-3-3:2013 listed in OJ. The product can be CE marked according to the Low Voltage Directive 2014/35/EU and EMC Directive 2014/30/EU provided also all other relevant requirements

## Factories

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD  
West Zone, Ji an County Industrial Park, Ji an County, Jiangxi Province,  
China

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd  
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong,  
China

Nemko Group AS  
Phillip Pedersens vei 11  
1366 Lysaker, Norway  
TEL +47 22 96 03 30  
info@nemko.com  
ENTERPRISE NUMBER  
NO974404532

Signature

Date of issue

Juan Saussey

Certification Department

04 / 11 / 2022

[www.nemko.com](http://www.nemko.com)

Page 2 of 2

Working for a more sustainable future- Please do not print