

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product LED Power Supply

Name and address of the applicant Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd. No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong

China

Name and address of the manufacturer Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd. No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong

China

Name and address of the factory See next page(s)

Note: When more than one factory, please report on page 2

Additional Information on Page 2

Ratings and Principal characteristics PRI: Max. 0.4 A, 220-240 V~, 50/60 Hz, More rating, see additional information.

Independent type, Class II; SELV, constant current output, thermal protected 110 °C, ta: 45 °C,

tc: 80 °C / 85 °C

Trademark /Brand (If any)

EAGLERISE

Customer's Testing Facility (CTF) Stage used

FLS-15-350 0-10 LA, FLS-25-600 0-10 LA, FLS-44-1050 0-10 LA, FLS-60-1700 0-10 LA, Model/Type Ref

FLS-60-1700 LA EXC, FLS-60-1500 LA EXC, FLS-60-1500 LD ECO, LS-40-xxxx LI ECO

Additional information(If necessary may also be

reported on Page 2)

✓ Additional Information on Page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017 IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

As shown in the Test Report Ref. No. which

forms part of this Certificate

REP007638

This CB Test Certificate is issued by the National Certification Body



Philip Pedersen vei 11, NO-1366 Lysaker, Norway Date: 15-03-2023

Jiyea Gim

Signature: Jiyea Gim

Certification department



NO126005

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd. No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong China

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD West Zone, Ji An County Industrial Park, Ji an County Jiangxi Province China

Additional Information (if necessary)

SEC:

FLS-15-350 0-10 LA: Max. 14.7 W, 0.12-0.35 A, 9-42 Vd.c. (under load), max. 59 Vd.c. (no-load) FLS-25-600 0-10 LA: Max. 25.2 W, 0.2-0.6 A, 9-42 Vd.c. (under load), max. 59 Vd.c. (no-load) FLS-44-1050 0-10 LA: Max. 44.1 W, 0.65-1.05 A, 9-42 Vd.c. (under load), max. 59 Vd.c. (no-load) FLS-60-1700 0-10 LA: Max. 61.2 W, 1.10-1.70 A, 12-42 Vd.c. (under load), max. 59 Vd.c. (no-load) FLS-60-1700 LA EXC: Max. 61.2 W, 1.10-1.70 A, 24-42 Vd.c. (under load), max. 55 Vd.c. (no-load)

FLS-60-1500 LD ECO and FLS-60-1500 LA EXC: Max. 63.0 W, 1.15-1.50 A, 24-42 Vd.c. (under load), max. 55 Vd.c. (no-load)

LS-40-xxxx LI EC0: Max. 40.4 W, 0.60-1.05 A, 24-42 Vd.c. (under load), max. 52 Vd.c. (no-load)

The 'xxxx' is for the output current and represents the number from 600 mA to 1050 mA in step of 50 mA, for example, 1050 means the output current is 1050 mA.



Philip Pedersen vei 11, NO-1366 Lysaker, Norway Date: 15-03-2023 Jiyea Gim

Signature: Jiyea Gim

Certification department