



Ref. Certif. No

NO121763/M2

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

LED Power Supply

## Name and address of the applicant

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.  
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong  
China

## Name and address of the manufacturer

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.  
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong  
China

## Name and address of the factory

See next page(s)

Note: When more than one factory, please report on page 2

 Additional Information on Page 2

## Ratings and Principal characteristics

PRI: LV supply: max. 1 A, 220-240 V~, 50/60 Hz, PF>0.95  
Centralized emergency power supply: 198-254 V DC  
SEC: LS-45-24 DALI2-DT8 LI and LS-45-24 DALI-2-DT8 LI: max.1.875 A, 24 Vdc, max.45 W  
LS-80-24 DALI2-DT8 LI and LS-80-24 DALI-2-DT8 LI: max.3.33 A, 24 Vdc, max.79.9 W  
LS-150-24 DALI2-DT8 LI, LS-150-24 DALI-2-DT8 LI and LS-150-24 DALI-2-DT8 LI2: max.6.25 A, 24 Vdc, max. 150 W  
Class II

## Trademark /Brand (If any)



## Customer's Testing Facility (CTF) Stage used

## Model/Type Ref

LS-45-24 DALI2-DT8 LI, LS-45-24 DALI-2-DT8 LI, LS-80-24 DALI2-DT8 LI, LS-80-24 DALI-2-DT8 LI, LS-150-24 DALI2-DT8 LI, LS-150-24 DALI-2-DT8 LI, LS-150-24 DALI-2-DT8 LI2

## Additional information (If necessary may also be reported on Page 2)

 Additional Information on Page 2

## A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017  
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

## As shown in the Test Report Ref. No. which forms part of this Certificate

REP012875  
This certificate replaces the certificate NO121763/M1, due to technical modification

This CB Test Certificate is issued by the National Certification Body

Philip Pedersen vei 11,  
NO-1366 Lysaker, Norway  
Date: 05-07-2023Signature: Sweet Yuan  
Certification department



Ref. Certif. No

NO121763/M2

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.  
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong  
China

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD  
West Zone, Ji An County Industrial Park, Ji an County  
Jiangxi Province  
China

### Additional Information (if necessary)

IP20, constant voltage output, thermal protected 110 °C,  
ta: 45 °C, tc: 80 °C / 85 °C, Independent controlgear providing SELV output, EOFv: 15%, MM marking



Philip Pedersen vei 11,  
NO-1366 Lysaker, Norway

Date: 05-07-2023

Signature: Sweet Yuan  
Certification department