



Ref. Certif. No

NO127769

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED Power Supply

Name and address of the applicant

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong
China

Name and address of the manufacturer

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong
China

Name and address of the factory

See next page(s)

Note: When more than one factory, please report on page 2

 Additional Information on Page 2

Ratings and Principal characteristics

PRI: max. 0.18 A, 220-240 V~, 50/60 Hz,
SEC: max. 21.0 W, max. 0.70 A, 2.8-84 V d.c. (under load), max. 98 V d.c. (no-load)
Built-in, constant current output, thermal protected 110 °C, providing SELV output. ta: 50 °C, tc:
80 °C / 85 °C

Trademark /Brand (If any)



Customer's Testing Facility (CTF) Stage used

Model/Type Ref

SS-6-XXX MB, CS-21-XXX MB, CS-21-XXX MB-G

Additional information (If necessary may also be reported on Page 2)

 Additional Information on Page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

REP015818

This CB Test Certificate is issued by the National Certification Body

Philip Pedersen vei 11,
NO-1366 Lysaker, Norway
Date: 11-09-2023Signature: Yasaman Vadoudi
Certification department



Ref. Certif. No

NO127769

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong
China

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China

Additional Information (if necessary)

The 'XXX' is for the output current and represents the number is 120 or from 150 to 700 in the step of 50.
For example, 700 means the output current is 700 mA.



Philip Pedersen vei 11,
NO-1366 Lysaker, Norway

Date: 11-09-2023

Signature: Yasaman Vadoudi
Certification department