


# ATTESTATION OF CONFORMITY

Issued to: Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.  
No.4, East Huanzhen Road, Beijiao Shunde, 528000 Foshan, Guangdong, China

For the product: LED Power Supply

Trade name:  EAGLERISE

Type/Model: LS-40-1000 RF-CCT LI, LS-60-800 RF-CCT LI,  
LS-60-1500 RF-CCT LI, LS-80-1000 RF-CCT LI,  
LS-80-1800 RF-CCT LI

Ratings: Class II, independent, IP20, ta: 45 °C, SELV, constant current output, 110 °C  
thermal protection, non-inherently short circuit proof;  
Other information refers to Attachment 5 of test report for "Detailed Model List"

Manufactured by: Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.  
No.4, East Huanzhen Road, Beijiao Shunde, 528000 Foshan, Guangdong, China

Requirements: EN 61347-1:2015 + A1:2021  
EN 61347-2-13:2014 + A1:2017  
EN 62493:2015

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 4908272.50.

This Attestation implies that the examined types are in accordance with the standards designated under the Low Voltage Directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 19 October 2023

Number: 4908272.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.,  
Guangzhou Branch



Miranda Zhou  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

