



Ref. Certif. No

NO128348/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED Power Supply

Name and address of the applicant

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong
China

Name and address of the manufacturer

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong
China

Name and address of the factory

See next page(s)

Note: When more than one factory, please report on page 2

Additional Information on Page 2

Ratings and Principal characteristics
Trademark /Brand (If any)

PRI: max. 0.18 A, 220-240 V~, 50/60 Hz, Cl. II
EAGLERISE



Customer's Testing Facility (CTF) Stage used

Model/Type Ref

LS-8-xxx SI2 E, LS-12-xxx SI2 E

Additional information (If necessary may also be reported on Page 2)

Additional Information on Page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

REP030880
This certificate replaces the certificate NO128348, due to technical modification.

This CB Test Certificate is issued by the National Certification Body



Philip Pedersen vei 11,
NO-1366 Lysaker, Norway
Date: 12-03-2024

Signature: Juan Z Saussey
Certification department



Ref. Certif. No

NO128348/M1

Foshan Eaglerise Power Science & Technology (Shunde) Co., Ltd.
No.4, East Huanzhen Road, Beijiao Shunde, Foshan, Guangdong
China

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China

Additional Information (if necessary)

SEC: max. 12.0 W, max. 0.3 A, 30-40 Vd.c. (under load), max. 59 Vd.c. (no load). Independent type, SELV, constant current output, thermal protected
110 °C, ta: 45 °C, tc: 75 °C / 80 °C.

The 'xxx' is for the output current and represents the number from 70 to 300, for example, 70 means the output current is 700 mA, 300 means the output current is 300 mA.



Philip Pedersen vei 11,
NO-1366 Lysaker, Norway

Date: 12-03-2024

Signature: Juan Z Saussey
Certification department