

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED driver
Name and address of the applicant	EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD West Zone, Ji An County Industrial Park, Ji An County, 343100 Ji An City, Jiangxi, China
Name and address of the manufacturer	EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD West Zone, Ji An County Industrial Park, Ji An County, 343100 Ji An City, Jiangxi, China
Name and address of the factory	EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD West Zone, Ji An County Industrial Park, Ji An County, 343100 Ji An City, Jiangxi, China
<i>When more than one factory</i>	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	Product data Ratings: IP20, SELV, λ : 0,1C-0,95 or 0,95, constant current output, 110 °C thermal protection, non-inherently short circuit proof, EL mark, ta: 45 °C, tc: 85 °C; With side covers: Class II, independent type; Without side covers: Double insulation, built-in type; Other information refers to model list of test report
Trademark / Brand (if any)	 or  EAGLERISE or ASTRAPOWER
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	FLX-42-1050 DALI-2 0-10 LN PRO
Additional information	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014 and IEC 61347-2-13:2014/AMD1:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	National differences: AU, EU Group Differences, GB, NZ 4918256.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-06-06

Signature: C. Lin