



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2021011002362526

NAME AND ADDRESS OF THE APPLICANT

Eaglerise Electric & Electronic (China) Co., Ltd.
No.A3, Guicheng Sci-Tech Industrial Park, Jianping Road, Nanhai District, Foshan City, Guangdong
Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Eaglerise Electric & Electronic (China) Co., Ltd.
No.A3, Guicheng Sci-Tech Industrial Park, Jianping Road, Nanhai District, Foshan City, Guangdong
Province, P.R.China

NAME AND LOCATION OF THE FACTORY

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An
County, Jiangxi Province, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Independent, Constant Current Mode, SELV,
ta:45°C , tc:75°C, Class II, IP20, Suitable For Direct Mounting On Normally Flammable Material,
Temperature Declared Thermally Protected: 110°C)
See Appendix. 220-240V ~ 50/60Hz

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17625.1-2022;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014).

Valid from: May.21,2024

Valid until: Jan.14,2026

Date of original issued: Jan.14,2021

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2021011002362526

Appendix: Page 1 of 1

序号	型号	输出电压范围 (Vdc)	输出电流 (mA)	最大输出电压 (Max.Vdc)	最大输出功率 (Max.W)
1	LS-21-300 MI	42-70	300	80	21
2	LS-21-350 MI	36-60	350	70	21
3	LS-21-400 MI	30-50	400	60	20
4	LS-21-450 MI	27-46	450	58	20.7
5	LS-21-500 MI	24-42	500	53	21
6	LS-21-550 MI	23-38	550	50	20.9
7	LS-21-600 MI	21-35	600	45	21
8	LS-21-650 MI	20-32	650	42	20.8
9	LS-21-700 MI	18-30	700	40	21

输入: 220-240V~ 50/60Hz

备注: 以上所有型号实测输入功率均大于 5W.

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.