



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---|---|
| Product | LED power supply |
| Name and address of the applicant | EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD West Zone, Ji An County Industrial Park, Ji An County, 343100 Ji An City, Jiangxi, China |
| Name and address of the manufacturer | EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD West Zone, Ji An County Industrial Park, Ji An County, 343100 Ji An City, Jiangxi, China |
| Name and address of the factory | EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD West Zone, Ji An County Industrial Park, Ji An County, 343100 Ji An City, Jiangxi, China |
| <i>When more than one factory</i> | <input type="checkbox"/> Additional information on page 2 |
| Ratings and principal characteristics | Product data Ratings: ta: 45 °C, SELV, independent, Class II, IP20, non-inherently short circuit proof, 110 °C thermal protection Product data – type LS-150-24 DALI-2 LI1, LS-45-24 DALI-2 LI1 and LS-80-24 DALI-2 LI1 Ratings: tc: 85 °C, EL-mark Product data – type LS-75-48 LI EXC Max. case temperature (tc): 90°C |
| Trademark / Brand (if any) |  or  EAGLERISE or ASTRAPOWER |
| Customer's Testing Facility (CTF) Stage used | |
| Model / Type Ref. | LS-150-24 DALI-2 LI1, LS-45-24 DALI-2 LI1, LS-75-48 LI EXC and LS-80-24 DALI-2 LI1 |
| Additional information | <input type="checkbox"/> Additional information on page 2 |
| A sample of the product was tested and found to be in conformity with | IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014 and IEC 61347-2-13:2014/AMD1:2016 National differences: AU, EU Group Differences, GB, NZ |

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-08-30


Signature: T. Baltzer 



Ref. Certif. No.

NL-110376

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

As shown in the Test Report Ref. No.
which forms part of this Certificate

4920145.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-08-30


Signature: T. Baltzer 