



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024011002715090

NAME AND ADDRESS OF THE APPLICANT

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An
County, Jiangxi Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An
County, Jiangxi Province, P.R.China

NAME AND LOCATION OF THE FACTORY

Eaglerise Electric & Electronic (Ji An) Co., Ltd.
Southwest Corner, Crossing Between Panlong Road And Chaoyang Road, Industrial Park, Ji An
County, Jiangxi Province, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

A.C. Supplied Electronic Control Gear For LED Modules(Independent, Constant Current Mode, SELV,
ta:45°C, tc:75/80/85°C, Class II, IP20, Non-dimmable, Suitable For Normally Flammable Material
Surfaces, Temperature Declared Thermally Protected: 110°C)
See Appendix; 220-240V~, 50/60Hz.

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17625.1-2022;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014).

Valid from: Oct.30,2024

Valid until: Oct.29,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024011002715090

Appendix : Page 1 of 1

序号	型号	输出电流 (mA)	输出电压 (Vdc)	最大输出 电压 (Vdc)	功率 (W) Max.	ta (°C)	tc (°C)
1	LS-8-120 LI1 EXC	120	27-42	59	5	45	75
2	LS-8-150 LI1 EXC	150	27-42	59	6.3		75
3	LS-8-160 LI1 EXC	160	27-42	59	6.7		75
4	LS-8-180 LI1 EXC	180	27-42	59	7.6		75
5	LS-8-200 LI1 EXC	200	27-40	59	8		75
6	LS-8-220 LI1 EXC	220	27-40	59	8.8		75
7	LS-12-250 LI1 EXC	250	27-42	59	10.5		75
8	LS-12-280 LI1 EXC	280	27-42	59	11.8		75
9	LS-12-300 LI1 EXC	300	27-40	59	12		75
10	LS-15-350 LI1 EXC	350	27-42	59	14.7		80
11	LS-21-400 LI1 EXC	400	27-42	59	16.8		85
12	LS-21-450 LI1 EXC	450	27-42	59	18.9		85
13	LS-21-500 LI1 EXC	500	27-42	59	21		85
14	LS-21-550 LI1 EXC	550	27-38.5	59	21.2		85

220-240V~, 50/60Hz

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.