



Ref. Certif. No

NO132715

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED Power Supply

Name and address of the applicant

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China

Name and address of the manufacturer

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China

Name and address of the factory

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China

Note: When more than one factory, please report on page 2

 Additional Information on Page 2Ratings and Principal characteristics
Trademark /Brand (If any)PRI: max. 0.27 A, 220-240 V~, 50/60 Hz
(EAGLERISE), (ASTRAPOWER)

Customer's Testing Facility (CTF) Stage used

Model/Type Ref

CS-xx-yyyy LI1

Additional information (If necessary may also be reported on Page 2)

 Additional Information on Page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

REP067754

This CB Test Certificate is issued by the National Certification Body

Philip Pedersen vei 11,
NO-1366 Lysaker, Norway
Date: 28-11-2024Signature: Juan Z Saussey
Certification department



Ref. Certif. No

NO132715

Additional Information (if necessary)

SEC: max. 42 W, max. 1.05 A, 24-42 Vd.c. (under load), max. 59 Vd.c. (no-load). Built-in LED power supply with double or reinforced insulation, providing SELV output, constant current output, thermally protected 110°C . ta: 70°C, tc: 100°C. The insulation between live parts and enclosure fulfils reinforced insulation, IP20, for indoor use. All models encapsulated by potting compound totally. In model name, the 'xx' in the type designation can be 24, 30 or 42. The 'yyyy' is for the output current and represents the number from 450 to 1050, for example, 450 means the output current is 450 mA, 1050 means the output current is 1050 mA.



Philip Pedersen vei 11,
NO-1366 Lysaker, Norway
Date: 28-11-2024

Signature: Juan Z Saussey
Certification department