

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

LED power supply

Name and address of the applicant

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji An County, 343100 Ji An City,
Jiangxi, China

Name and address of the manufacturer

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji An County, 343100 Ji An City,
Jiangxi, China

Name and address of the factory

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji An County, 343100 Ji An City,
Jiangxi, China*When more than one factory* Additional information on page 2

Ratings and principal characteristics

Product dataRatings: Independent type, Class II, SELV, ta: 45 °C, tc: 85 °C,
non-inherently short circuit proof, IP20;
Input: 220-240 V~, 50/60 Hz, 0,28 A max.;
Output: 24-40 Vdc, max. 59 Vdc, constant current 1000 mA,
40 W max.

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LS-40-1000 CCT LI and LS-40-1000 CCT LI-XSD

Additional information

 Additional data information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014
and IEC 61347-2-13:2014/AMD1:2016**National differences:**

AU, EU Group Differences, GB, NZ

As shown in the Test Report Ref. No.
which forms part of this Certificate

4927863.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-12-04

Signature: Carol Jwo