

CERTIFICATE

Issued to:
Applicant:
**EAGLERISE ELECTRIC & ELECTRONIC (JI AN)
CO., LTD**
West Zone, Ji An County Industrial Park, Ji An
County
343100 Ji An City, Jiangxi, China

Licensee:
**Foshan Eaglerise Power Science & Technology
(Shunde) Co.,Ltd.**
No.4, East Huanzhen Road, Beijiao Shunde
528000 Foshan, Guangdong, China

Product : LED power supply
Trade name(s) : EAGLERISE
Type(s)/model(s) : LS-40-1000 CCT LI and LS-40-1000 CCT LI-XSD

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 61347-1:2015, EN 61347-1:2015/A1:2021, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2178893


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.


This certificate is issued on 4 December 2024 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-150488

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Kate Xu
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: LED power supply
Trade name(s)	: EAGLERISE
Type(s)/model(s)	: LS-40-1000 CCT LI and LS-40-1000 CCT LI-XSD
Rated voltage	: 220-240 V~
Rated frequency	: 50/60 Hz
Rated input current	: 0,28 A max.
Power factor	: ≥ 0.9
Rated output voltage	: 24-40 Vdc
Rated output current	: constant current 1000 mA
Rated output power	: 40 W max.
Degree of protection	: IP20
Ambient temperature (ta)	: 45 °C
Max. case temperature (tc)	: 85 °C
Additional information	: Independent type, SELV, non-inherently short circuit proof

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN IEC 62384:2020

Test result

The test results are documented in DEKRA test file 492786300.

Additional information

The list of components is laid down in test report 4927863.50,4927863.51.

Conclusion

The examination has confirmed that all requirements were met.

Factory location

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji An County
343100 Ji An City, Jiangxi, China

Trade name : EAGLERISE stands for The logo for EAGLERISE, which consists of a stylized eagle head profile in black above the word "EAGLERISE" in a bold, black, sans-serif font.