



Ref. Certif. No

NO133325

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED Power Supply

Name and address of the applicant

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China


Name and address of the manufacturer

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China

Name and address of the factory

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD
West Zone, Ji An County Industrial Park, Ji an County
Jiangxi Province
China

Note: When more than one factory, please report on page 2

 Additional Information on Page 2Ratings and Principal characteristics
Trademark /Brand (If any)PRI: max. 0.25 A, 220-240 V~, 0/50/60 Hz
EAGLERISE & ASTRAPOWER

Customer's Testing Facility (CTF) Stage used

Model/Type Ref

FLS-21-500 LD1 EXC, FLS-30-700 LD1 EXC, FLS-38-900 LD1 EXC, FLS-40-1050 LD1 EXC,
FLS-42-1050 DALI-2 LD-R

Additional information (If necessary may also be reported on Page 2)

 Additional Information on Page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

REP074521

This CB Test Certificate is issued by the National Certification Body

Philip Pedersen vei 11,
NO-1366 Lysaker, Norway
Date: 21-01-2025Signature: Yasaman Vadoudi
Certification department



Ref. Certif. No

NO133325

Additional Information (if necessary)

Centralized emergency power supply: 220-240 VDC

SEC: Max. 42 W, max. 1.05 A, 9-42 Vd.c. (under load),
max. 59 Vd.c. (no-load).

EOF1: 100% (For models FLS-21-500 LD1 EXC, FLS-30-700 LD1 EXC, FLS-38-900 LD1 EXC and FLS-40-1050 LD1 EXC)

EOF1: 15% (For model FLS-42-1050 DALI-2 LD-R)

Independent type with terminal cover incl. strain relief, Class II;

Built-in type without terminal cover. SELV, constant current output, thermal protected 110 °C, ta: 45 °C, tc: 85 °C / 90 °C.



Philip Pedersen vei 11,
NO-1366 Lysaker, Norway

Date: 21-01-2025

Signature: Yasaman Vadoudi
Certification department