

ENEC

NO5175



Nemko hereby grants the following manufacturer license to affix the above shown ENEC mark on the product(s) specified below

Applicant

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD West Zone, Ji An County Industrial Park, Ji an County

Jiangxi Province

China

Manufacturer

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD West Zone, Ji An County Industrial Park, Ji an County

Jiangxi Province

China

Factory

EAGLERISE ELECTRIC & ELECTRONIC (JI AN) CO., LTD West Zone, Ji An County Industrial Park, Ji an County

Jiangxi Province

China

Project Number

PRJ0071959

Product

LED Power Supply

Model/Type Ref.

FLS-21-500 LD1 EXC, FLS-30-700 LD1 EXC, FLS-38-900 LD1 EXC, FLS-40-1050 LD1

EXC, FLS-42-1050 DÁLI-2 LD-R

Ratings

PRI: max. 0.25 A, 220-240 V~, 0/50/60 Hz

Brandname / TradeMark

EAGLERISE & ASTRAPOWER

Principal Characteristics

EAGLERISE + ASTRA

A sample of the product was tested and found to be in conformity with

Safety

EN 61347-1:2015;A1 EN 61347-2-13:2014;A1 EN IEC 62384:2020

Test report No

REP074521, REP074520

Compliance

The conditions for this licence are that the ENEC-marked products conform with the applicable Standard(s) as stated in the test report and that Articles 8 and 9 of the ENEC Agreement are fulfilled by the manufacturer. The mark signifies the compliance of the completed products with these conditions. Further information is given in the attached Annex, which forms an obligatory part of this licence document. This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessay legal rights with regards to the production presented for the testing and certification

Additional Information

See next page

Additional model(s)

No additional models

Signature

Nemko Group AS Philip Pedersens vei 11 1366 Lysaker, Norway TEL +47 22 96 03 30 info@nemko.com ENTERPRISE NUMBER NO974404532

Date of Issue

Yasaman Vadoudi

Yasaman Vadoudi

Certification department

2025-01-21

Working for a more sustainable future Please do not print



www.nemko.cor



ENEC

NO5175



Additional Information

Centralized emergency power supply: 220-240 VDC SEC: Max. 42 W, max. 1.05 A, 9-42 Vd.c. (under load), max. 59 Vd.c. (no-load). EOFI: 100% (For models FLS-21-500 LD1 EXC, FLS-30-700 LD1 EXC, FLS-38-900 LD1 EXC and FLS-40-1050 LD1 EXC) EOFI: 15% (For model FLS-42-1050 DALI-2 LD-R) Independent type with terminal cover incl. strain relief, Class II; Built-in type without terminal cover. SELV, constant current output, thermal protected 110 °C, ta: 45 °C, tc: 85 °C / 90 °C.

Signature

Nemko Group AS Philip Pedersens vei 11 1366 Lysaker, Norway TEL +47 22 96 03 30 info@nemko.com ENTERPRISE NUMBER NO974404532

Date of Issue

Yasaman Vadoudi

Yasaman Vadoudi

Certification department

2025-01-21

Working for a more sustainable future Please do not print



<u>www.nemko.com</u>